



Enel CO₂ Post-Combustion Capture Project: Brindisi Pilot Plant

Angela Mangiaracina

Enel - Engineering & Innovation Division


European CCS Demonstration Project Network

Brindisi, 16 February 2011

ZEPT – R&D supporting activities

Pilot Stage – Brindisi CO₂ Capture Pilot Plant

- At the site of **Brindisi** coal fired power station a pilot plant for CO₂ separation via amine scrubbing is in operation. The plant is installed on the Unit 4.
- The plant is composed by a flue gas pre-treatment section (able to remove completely the particulate and the SO₃ and to reduce SO₂ level below 20 mg/Nm³) and by a CO₂ separation unit
- The plant size is **10.000 Nm³/h**, capturing about **2,5 t/h of CO₂**
- Target: gain experience in CCU designing and operation, and assess the environmental impact of the process





ZEPT- CO₂ capture pilot plant

Flue gas pre-treatment

The pre-treatment plant gives the possibility to partially bypass both the WFGD and the WESP

Pilot plant general flow diagram





ZEPT- CO₂ capture pilot plant

CO₂ separation unit

Absorber

- 1.5 m Internal diameter
- 3 structured packing sections (22 m total)
- Solvent flow rate : 20 to 80 m³/h

Pilot plant general flow diagram




Stripper

- 1.2 m Internal diameter
- 3 random packing sections (10 m total)
- Operative pressure up to 2.5 bar

ZEPT- R&D Supporting Activities

Brindisi Sud Pilot Plant : Project Schedule



- ✓ About one year for site construction activities
- ✓ Less than 2 years to first CO₂ separation since starting detailed engineering

ZEPT – R&D supporting activities

CO₂ Capture pilot plant : Research Program


- **Operational experience (MEA 20%- 30%+ inhibitors)**
 - Assessment of the MEA absorption technology: reliability, environmental impact, power consumption and capture performance
 - Definition of operating procedures, management
 - Cost evaluation at different operating conditions for retrofit application: solvent consumption, inhibitors, waste treatment management
 - Flue gas composition: CO₂ stream and emissions
- **Advanced solvent and inhibitor testing**
 - Reduction of power consumption (reduction of operating cost)
 - Solvent degradation (reduction of operating cost)
 - Assessment of corrosion (reduction of capital cost)
 - Reaction rate (check of design parameters)
 - Environmental performances

Base line campaign

General Performance of 20% MEA


Main process parameters

	U.M	07_09	08_09	09_09
Portata Fumi	Nmc/h	10.000	12.000	3.000
O ₂ in abs	% vol dry	12,00	11,5	11,5
Efficienza di cattura	%	90	88	98
Portata solvente	mc/h	52	60	25
CO ₂ separata (liq)	kg/h	1830	2300	800
Consumo energetico (liq)	Gj/ton CO ₂	4,12	3,69	5,06




Mass balance check


*TEST 07_09_2010



*TEST 08_09_2010




*Test 09_09_2010



The first test campaign

Campaign schedule – 30% MEA



MEA 30 % test run:


- ✓ 500 hours of parametric tests (Nov 15 – 21 Jan)
- ✓ 500 hours of continuous operation (24 Jan – 11 Feb)
- ✓ Reclaiming procedure to be tested at the end
- ✓ Emission campaign
- ✓ Wet pressure drop tests by IFPEN
- ✓ Corrosion Monitoring

The test campaign with 30% MEA


Settings Applied in the Test with Continuous Operation

The following settings have been applied in the 500 hours test (Jan 07 – Feb 11):

- Flue gas flow: 10.000 Nmc/h
- Solvent flow: 30 mc/h
- Stripper pressure: 0.8 barg
- Corrosion coupon are installed: CS 018; SS 316; SS 304



Steam consumption: » 3.4 GJ/ton CO₂



Average CO₂ capture: 90 %



Thank you!

Angela Mangiaracina

Research Technical Area

ENEL Engineering and Innovation Division

Mail : angela.mangiaracina@enel.com